



Certificate of constancy of performance according to AVCP-System 1

MPA Eberswalde

Materialprüfanstalt
Brandenburg GmbH

0763-CPR-9118

Prüfung, Überwachung,
Zertifizierung, Gutachten,
Forschung und Entwicklung

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR) this certificate applies to the construction product

INNOVUS® DP MDF FIRE X CARB2/TSCA

MDF according to EN 622-5, for non-load-bearing interior applications, 16 mm to 30 mm thickness, density range $800 \text{ kg/m}^3 \pm 40 \text{ kg/m}^3$, product code "BGAL1", double-sided coated with decor paper in any colour, optional raw board dyed red, reaction to fire classification according to EN 13501-1: B-s1,d0.

This classification is valid for the following end use conditions acc. to classification report KB-Hoch-250658, 04.06.2025: If fixed in front of underlying materials, these have to be at least of class A1 or A2-s1,d0, at least 9 mm thick and a density of no less than 653 kg/m^3 . The distance of the product to these underlying materials must be at least 40 mm.

Gypsum plasterboards are exempt as underlying materials and must not be used.

produced by

Sonae Arauco Deutschland GmbH

Grecostraße 1, 49716 Meppen, Deutschland

and produced in the manufacturing plant

Grecostraße 1, 49716 Meppen, Deutschland (panel)

Radinkendorfer Straße 71, 15848 Beeskow, Deutschland (coating)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 13986:2004+A1:2015

under system 1 for the performances set out in this certificate are applied and that the construction product fulfils all the prescribed requirements for these performances.

This certificate hereby replaces the certificate 0763-CPR-9118, dated 10.09.2020, and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product and the manufacturing conditions in the plant are not modified significantly.

Eberswalde, 21.11.2025



Dr. Robby Wegner
Head of Certification Body

Sparkasse Schwandorf
Kto-Nr.: 100 164 862
BLZ: 750 510 40
IBAN: DE55 7505 1040 0100 1648 62
BIC-/SWIFT: BYLADEM1SAD
USt.-Id. DE814335485
Finanzamt Eberswalde



Die Akkreditierung gilt nur für die in der Urkunde aufgeführten Verfahren.



vom DIBt anerkannte
PÜZ-Stelle BRA02



EC notified 0763



CARB notified TPC 18